

**अप्रैल - जून 2024 (1st तिमाही 2024-25) के दौरान निम्नो बाजगो पावर स्टेशन के लिए नामांकन के आधार पर किए गए कार्यों/खरीद का विवरण**

1	2	3	4	5	6	7	8	9	
SL No	Computer No.	Name of Work	Letter of Awarded No. and date	Name of Contractor	Amount (Rs.in Lakh)	Date of Start and duration of work	Schedule date of Completion	Reason for awarding on Nomination basis	End User Division
सएल नं	कंप्यूटर नं.	मद/कार्य की प्रकृति	पुरस्कार पत्र संख्या और तारीख	ठेकेदार का नाम	अनुबंध का मूल्य	प्रारंभ की तिथि और कार्य की अवधि	एनआईटी . के प्रकाशन की तिथि	नामांकन के आधार पर लेटर ऑफ़ अवार्ड देने का कारण	आपूर्ति की समाप्ति की निर्धारित तिथि
1	120717	Condition Monitoring Testing (Shell Lube Analysis) of Shell S2 V32 Tellus oil.	NH/NBPS/C&P/LOA-415/2024/170 Dated 18.06.2024	M/s R. B Technosol Head Office, Near Khushal Enclave, Village Pabhat, Zirakpur-14060	₹35,872.00	19-06-2024	19-07-2024	As per the guidelines of the original manufacturer of Power Packs, it was necessary to test the hydraulic oil from time to time to know its condition. Hydraulic oil was tested in the past as well, & needs to be tested every year. Keeping in view of above, it was proposed to get the Condition Monitoring Testing of hydraulic oil of all the eight Power Packs installed in the dam complex. As per the guidelines of the original manufacturer, it was mandatory and very necessary to do Condition Monitoring Testing every year to know the current condition of hydraulic oil of all the eight Power Packs for operation of gates.	30 Days

*Rishabh*  
03/07/2024