

**जनवरी-मार्च 2025 (4<sup>th</sup> तिमाही 2024-2025) के दौरान निम्नो बाजगो पावर स्टेशन के लिए नामांकन के आधार पर किए गए कार्यों/खरीद का विवरण**

SL No	1 Computer No.	2 Name of Work	3 Letter of Awarded No. and date	4 Name of Contractor	5 Amount (Rs.in Lakh)	6 Date of Start and duration of work	7 Schedule date of Completion	8 Reason for awarding on Nomination basis	9 End User Division
सल नं	कंप्यूटर नं.	मद/कार्य की प्रकृति	पुरस्कार पत्र संख्या और तारीख	ठेकेदार का नाम	अनुबंध का मूल्य	प्रारंभ की तिथि और कार्य की अवधि	एनआईटी. के प्रकाशन की तिथि	नामांकन के आधार पर लेटर ऑफ़ अवार्ड देने का कारण	आपूर्ति की समाप्ति की निर्धारित तिथि
1	137225	Annual Recharge against 14 nos. Airtel DTH Connection installed at NBPS, Alchi.	NH/NBPS/C&P/2024-25/WO-35/14 Dated:16-01-2025	M/s 4G Communication Ganderbal, J&K Pin-191201	₹56,086.00	17-01-2025	27-01-2025	14 nos. of set top boxes (STBs) installed at Leh Transit camp/HOP Office/HOP Residence/Powerhouse control room/VIP Guest house & annual recharge was to be done time to time through Electrical Infra Division NBPS. The validity of the recharge was expired on 03 February 2025. Since Nimmo Bazgo Power Station is located in a remote location and no other service provider was not willing to provide services at NBPS, Alchi. Due to unavoidable and exceptional circumstances, the same was proposed through nomination basis.	
2	137264	Repair of fault including replacement of damaged coil(s) in stator winding of Unit-1 of Power House at NBPS.	NH/NBPS/C&P/2024-25/WO-36/15 Dated:17-01-2025	M/s Anvee Hydroelectric Power Growth Pvt. Ltd, 169 Karamveer Nagar, B.H.E.L. Bhopal(MP) -462021.	₹1000000.00	18-01-2025	28-02-2025	Unit-1 tripped on 30-11-2024 at 22:33 Hrs due to fault in R1 parallel path of R-Phase, so after restoration of said unit again unit was tripped on 09.01.2025.  After the tripping incident, analysis of DR (Disturbance Record) of the numerical protection relay, it was found that there is fault in Y-Phase of the winding. Accordingly, all electrical tests of the winding were carried out. During the said testing it was observed that fault was in Y1 parallel path of Y-Phase. After confirmation of the existence of fault in Y1 path, it was decided to carry out the physical inspection of the winding. During physical inspection on both top and bottom sides of the overhang portion of the winding, no sign of possible fault location was visible.  Through open tendering, it would take longer time (at least 3 months) to award the work, which would delay in executing the restoration work. An extended forced outage would result in loss of PAF. Keeping in view of the above fact, it was proposed to execute the work through nomination basis to restore Unit-I at the earliest.	

*[Handwritten Signature]*

SL No	Computer No.	Name of Work	Letter of Awarded No. and date	Name of Contractor	Amount (Rs.in Lakh)	Date of Start and duration of work	Schedule date of Completion	Reason for awarding on Nomination basis	End User Division
सएल नं	कंप्यूटर नं.	मद/कार्य की प्रकृति	पुरस्कार पत्र संख्या और तारीख	ठेकेदार का नाम	अनुबंध का मूल्य	प्रारंभ की तिथि और कार्य की अवधि	एनआईटी . के प्रकाशन की तिथि	नामांकन के आधार पर लेटर ऑफ़ अवार्ड देने का कारण	आपूर्ति की समाप्ति की निर्धारित तिथि
3	110686	Servicing of one (01) nos. Kiloskar make 100 kVA DG sets installed at Leh Transit camp.	NH/NBPS/C&P/WO-37/2024-25/ 25 Dated:23.01.2025	M/s Suraj motor Store, Airport Road, Skalzangling, Leh	₹16,023.00	23.01.2025	10.02.2025	100 KVA DG set is installed for continuous power supply in guest house/Transit camp. Overhauling of DG set was done in June 2024 and servicing & overhauling of the DG set was required as recommended by OEM. Since the execution value for the said work was to Rs. 16,023.00. In view of adverse climatic condition & smooth functioning/ operational overhauling work was carried out through M/s Suraj motor Store, Airport Road, Skalzangling, Leh through work order basis.	
4	137008	Comprehensive detail Health assessment of Dam structures of Nimoo Bazgo Power Station, NHPC Limited	NH/NBPS/C&P/2024-25/WO-38/104 Dated:10-02-2025	M/s Centre for Construction Development & Research National Council for Cement and Building Materials, Ballabhgarh, Haryana- 112004	₹ 14,61,000.00			As per Clause 38, of Dam Safety Act, the owner of the dam shall make comprehensive dam safety evaluation through an independent panel of experts constituted as per regulations for the purpose of determining the conditions of the specified dam and its reservoir. As per Clause 22 of Dam Safety act it is responsibility of Dam Owner to compile all technical documentation concerning hydrology, dam foundation and structural engineering of the dam. Evaluation of many projects of NHPC were awarded to M/s National Research Centre for Development and Research (NCCBM), Ballabhgarh, Haryana (a Government organization) and successfully conducted by them. Keeping in view of the above fact, the above work was awarded through nomination basis to M/s National Research Centre for Development and Research (NCCBM), Ballabhgarh, Haryana (a Government organization).	Under Process in Enduser Division