

DETAILS OF CONTRACTS CONCLUDED DURING THE MONTH JUNE, 2026													
1 TENDER NO.	2 ITEM/ NATURE OF WORK	3 MODE OF TENDER ENQUIRY	4 DATE OF PUBLICATION OF NIT	5 TYPE OF BIDDING (SINGLE/TWO BID SYSTEM)	6 LAST DATE OF RECEIPT OF TENDER	7 NOS. OF TENDER RECD.	8 NOS. AND NAMES OF PARTIES QUALIFIED AFTER TECHNICAL EVALUATION	9 NOS. AND NAMES OF PARTIES NOT QUALIFIED AFTER TECHNICAL EVALUATION	10 WHETHER CONTRACT AWARDED TO LOWEST TENDERER/ EVALUATED L1	11 CONTRACT NO. & DATE	12 NAME OF CONTRACTOR	13 VALUE OF CONTRACT (In Rs.)	14 JUSTIFICATION FOR AWARD OF CONTRACT ON SINGLE TENDER/WORK ORDER
1	Repair work of 2 nos electric panels of Radial gates at Dam	Work Order	-	-	-	-	-	-	-	NH/CPS-1 /DAM/2026/39 Dated: 02.06.2026	M/s ITL Industries Ltd, Indore (MP)	202103.00	During a routine inspection, it was observed that the electrical panels of the Radial Gates were not functioning properly due to faults in the switchgear components. The repairs were carried out on an urgent basis prior to the onset of the monsoon season to ensure safe and uninterrupted operation of the gates
2	Construction of two nos. shades and three nos. platforms for Installation of 6 nos. strong motion accelerographs at Chamera-I Power Station	Work Order	-	-	-	-	-	-	-	NH/CPS-1 /DAM/2026-27/25 Dated: 04.06.2026	MNAK INFRA CONSTRUCTION LLP, Vill. Khairi, PO- Samleu, Tehsil Dalhousie, Distt. Chamba (H.P.)- 176325.	222457.00	Urgent civil works were required for the installation of SMA at the identified locations, as the SITC work had already been awarded to M/s AIMIL India Ltd. Any delay in the civil works would have adversely affected the installation and commissioning schedule of the SMA systems.
3	Calibration of Cambridge Sensotec Make SF6 Gas Quality Analyzer of CPS-1	Work Order	-	-	-	-	-	-	-	NH/CPS-1/PH-SY/E-172410/WO/2026-27/19 Dated: 16.06.2026	M/s. Applied Techno Products Pvt. Ltd.,	88500.00	For the calibration of the SF6 Gas Quality Analyzer to enable accurate conduct of gas purity tests for the GIS, the work was awarded to Authorized Dealer of the OEM, M/s Applied Techno Products Pvt. Ltd.
4	R&M of Project Hospital by way of Providing Para-Medical staff and Cleaning & Sweeping Staff	Work Order	-	-	-	-	-	-	-	NH/CPS-1 /Hosp./Khairi/2026-27/232 Dated: 24.06.2026	M/s Arvind Kumar, Govt. Contractor Village Chambi, P.O. Sudli, Tehsil Dalhousie, Distt. Chamba (HP) 176303	753238.00	The tendering process was initiated following the cancellation of the previous contract for the deployment of para-medical and sweeping staff for the R&M works of the hospital at Chamera-I Power Station. However, the award of the new contract was expected to take some time. To ensure uninterrupted hospital services, the work was awarded on nomination basis for a period of two months (June 2026 to July 2026) to M/s Arvind Thakur.
5	Repair of Motor of Hydraulic Pump of Sluice Gate power pack	Work Order	-	-	-	-	-	-	-	NH/CPS-1 /DAM/2026/159 Dated: 30.06.2026	M/s India Electric works, Pathankot	66717.00	During a routine inspection, it was observed that the hydraulic motor of the Sluice Gate was not functioning due to damaged winding and bearings. The repairs were undertaken on an urgent basis prior to the onset of the monsoon season to ensure proper operation of the gate.

DGM (P&E) →

Arpit
SM (Tech)

Panki
CIE Mech