

**NHPC LIMITED**  
(A Government of India Enterprise)  
Regd. Office: NHPC Office Complex, Sector-33, Faridabad-121003 (Haryana)

**Corrigendum-III.**

Date: 26.08.2023

**Name of work:** Supply, Erection, Testing & Commissioning of 02 Nos. TRCM for Subansiri Lower HE Project (2000 MW).

**Gem Bid ID No.:** GEM/2023/B/3667951

**Tender Reference No.:** NH/CC-IV/CO-260/PR11521/260 dated 10.07.2023

**A. Amendment proposed as under:**

Sl. No.	Tender Clause	Amendment
1	Section-III (SCC) Annexure-1A:	Amended Annexure-1A is enclosed
2	Clause. 2.4(B) of PTS	The paragraph of Cl. 2.4(B) of PTS i.e. "It shall not be..... limit switches shall not be used." shall be replaced with <b>"It shall not be possible to travel whilst hoisting or lowering the trash rack. Each end of the rail track is to be protruding actuating ramps to limit gantry travel along with limit switches."</b>
3	Clause 2.3 of PTS Design/ operation required	Following is deleted <del>"It should be possible to sweep the floating debris to one side of Intake with moving lateral comb."</del>

**B. Reply to the Bidder's Queries are as under:**

Sl. No.	Bidder's Queries	Reply
1	Clause 2.2 of Technical Data Request regarding amend the quantity as two (2) set, in place of 1 set as per scope of work.	Number of TRCM required is 01 Set (02 Nos).
2	Cl. 2.2 of Technical Data Regarding Raking bucket lowering speed	Tender conditions shall prevail
3	Cl. 2.4 of PTS Clarification on Grade of Stainless Steel for Rake Bucket	Material already specified at GTS Clause 2.3 (A) (iv)
4	Clause No. 2.4 (A,) of PTS: Request regarding change in the operating parameters of the components of TRCM	Tender conditions shall prevail
5	Cl. 2.7 of PTS/Cl.5.2.8 Wireless Remote Control Clarification on equipment	Tender conditions shall prevail
6	Cl 4.0 of Integrity Pact Clarification regarding period of previous Transgression.	Tender conditions shall prevail

*Prust*


Sl. No.	Bidder's Queries	Reply
7	Clause 14.0 of SCC Request for amendment in the Terms of payment	Tender conditions shall prevail
8	Price Variation / Escalation: Request regarding incorporation of the Escalation formula against supply and erection portion of the order.	Tender conditions shall prevail
9	BOQ Statement 1 Request regarding amendment in BOQ	Tender conditions shall prevail
10	Cost of Bidding Documents	Cost of Bidding Document not applicable
11	Clarification regarding Site facilities: (i) Electricity for Erection, Testing and Commissioning.  (ii) Crane of suitable capacity will be provided for erection and commissioning of the TRCMs.  (iii) Any modification or repair in existing Trash Racks to suit TRCM raking will be in client's scope.  (iv) Any Civil work or any other kind of work/ modification/ rectification required at the existing site during Erection & Commissioning shall be in client scope.	(i) One power point at each Intake slab area (total 2 points) shall be provided by the Project site and remaining connections from these two power points shall be in the scope of TRCM Contractor.  (ii) Crane for erection and commissioning of the TRCMs shall be arranged by the TRCM Contractor  (iii) It is confirmed that any Modification/ repair in existing Trash racks (if any) to suit TRCM raking will be in the scope of NHPC.  (iv) It is also confirmed that modification/ rectification, if required, in Civil structure matching with TRCM as per tender documents shall be in the scope of NHPC.

**C. NIT Clause 1.2 ,The critical dates of the tender are modified as under:**

Sl. No.	Description	Extended Date/Time
iii)	Bid End Date/Time	22.09.2023 (15:00Hrs)
vi)	Bid Opening Date/ Time (Technical-bid)	26.09.2023 (15:30Hrs)

All other terms and conditions of the tender document shall remain unchanged.

**For & on behalf of NHPC Ltd.  
Tender Inviting Authority & Contact Person**

  
26/8/23

**General Manager (CC-IV),**  
Contracts (Civil) Division,  
2nd Floor, NHPC Office Complex,  
Sector-33, Faridabad-121003 (Haryana),  
Tele # 0129-2254677  
Email: contcivil4-co@nhpc.nic.in

**AMENDED LIST OF PREFERRED VENDORS FOR  
MAJOR COMPONENTS OF TRCM**

The following listed Vendors are preferred for various major components of Hydraulic TRCM. Where more than one vendor is listed, the Contractor is free to choose any of them.

Sl. No.	Major Items of TRCM	Name of Vendors
1	Hydraulic Cylinder	(i) Rexroth (ii) Hydrodyne (iii) Hunger (iv) Montan (v) Eaton (vi) <u>M/s Suvera Hydraulics</u>
2.	Hydraulic Power Packs	(i) Rexroth (ii) Vickers (iii) Montan (iv) Eaton (v) <u>M/s Suvera Hydraulics</u>
3.	Spherical / Roller/ Cylinder Clevis Bearing	(i) SKF (ii) FAG (iii) NTN (iv) INA (v) Tenmat
4	Flow Control Valves	(i) Rexroth (ii) Eaton (iii) <u>M/s Ployhydron</u> (iv) <u>M/s Yuken</u>
5	Self-priming, positive displacement axial piston type pump (bent axis)	(i) Rexroth (ii) Eaton (iii) Hydac (iv) <u>M/s Ployhydron</u> (v) <u>M/s Yuken</u>
6	Motor	(i) Bharat Bijlee (ii) Crompton Greaves (iii) GEC (iv) ABB (v) NGEF (vi) Marathon (vii) Siemens (viii) Alstom (ix) Kirloskar (x) <u>M/s Bonfiglioli Transmission</u>
7.	Gear box	(i) New Allenburry (ii) Elecon (iii) Premium (iv) Shanthi (v) Allroyd/NAW

*Signature*

8	Brakes (DC-Electro-Magnetic and Thruster)	(i) Electromag (ii) Sterling Control (iii) Strom Kraft (iv) AEC (v) Speed-o-control
9.	Couplings	(i) Mark-AEC (ii) Lovejoy (iii) Meco (iv) <u>M/s Flexocon</u>
10	Cable reeling drums	(i) Orton (ii) Mitool (iii) Crane Tech (iv) Bengal Technocrats
11	Hydraulic hose reeling drum	(i) Hanney Reels (ii) Mitool (iii) SP Engineers (iv) Elektromag (v) Reeltec

*Amst*