



Bid Number/बोली क्रमांक (बिड संख्या):
GEM/2023/B/4364653
Dated/दिनांक : 11-01-2024

Bid Document/ बिड दस्तावेज़

Bid Details/बिड विवरण	
Bid End Date/Time/बिड बंद होने की तारीख/समय	01-02-2024 21:00:00
Bid Opening Date/Time/बिड खुलने की तारीख/समय	01-02-2024 21:30:00
Bid Offer Validity (From End Date)/बिड पेशकश वैधता (बंद होने की तारीख से)	120 (Days)
Ministry/State Name/मंत्रालय/राज्य का नाम	Ministry Of Power
Department Name/विभाग का नाम	Na
Organisation Name/संगठन का नाम	Nhpc Limited
Office Name/कार्यालय का नाम	Dibang Multipurpose Project Roing
Total Quantity/कुल मात्रा	2
Item Category/मद केटेगरी	High Mast Lighting Tower for large area with LED Flood Lighting System (Q3)
Minimum Average Annual Turnover of the bidder (For 3 Years)/बिडर का न्यूनतम औसत वार्षिक टर्नओवर (3 वर्षों का)	20 Lakh (s)
OEM Average Turnover (Last 3 Years)/मूल उपकरण निर्माता का औसत टर्नओवर (गत 3 वर्षों का)	50 Lakh (s)
Years of Past Experience Required for same/similar service/उन्हीं/समान सेवाओं के लिए अपेक्षित विगत अनुभव के वर्ष	3 Year (s)
MSE Exemption for Years Of Experience/अनुभव के वर्षों से एमएसई छूट/ and Turnover/टर्नओवर के लिए एमएसई को छूट प्राप्त है	Yes
Startup Exemption for Years Of Experience/अनुभव के वर्षों से स्टार्टअप छूट/ and Turnover/ टर्नओवर के लिए स्टार्टअप को छूट प्राप्त है	Yes
Document required from seller/विक्रेता से मांगे गए दस्तावेज़	Experience Criteria,Past Performance,Bidder Turnover,Certificate (Requested in ATC),OEM Authorization Certificate,OEM Annual Turnover *In case any bidder is seeking exemption from Experience / Turnover Criteria, the supporting documents to prove his eligibility for exemption must be uploaded for evaluation by the buyer

Bid Details/बिड विवरण	
Past Performance/विगत प्रदर्शन	50 %
Bid to RA enabled/बिड से रिवर्स नीलामी सक्रिय किया	No
Type of Bid/बिड का प्रकार	Two Packet Bid
Time allowed for Technical Clarifications during technical evaluation/तकनीकी मूल्यांकन के दौरान तकनीकी स्पष्टीकरण हेतु अनुमत समय	2 Days
Inspection Required (By Empanelled Inspection Authority / Agencies pre-registered with GeM)	No
Estimated Bid Value/अनुमानित बिड मूल्य	1824988
Evaluation Method/मूल्यांकन पद्धति	Total value wise evaluation

EMD Detail/ईएमडी विवरण

Advisory Bank/एडवाइजरी बैंक	State Bank of India
EMD Amount/ईएमडी राशि	36000

ePBG Detail/ईपीबीजी विवरण

Advisory Bank/एडवाइजरी बैंक	State Bank of India
ePBG Percentage(%) / ईपीबीजी प्रतिशत (%)	10.00
Duration of ePBG required (Months) / ईपीबीजी की अपेक्षित अवधि (महीने).	26

(a). EMD EXEMPTION: The bidder seeking EMD exemption, must submit the valid supporting document for the relevant category as per GeM GTC with the bid. Under MSE category, only manufacturers for goods and Service Providers for Services are eligible for exemption from EMD. Traders are excluded from the purview of this Policy./जेम की शर्तों के अनुसार ईएमडी छूट के इच्छुक बिडर को संबंधित केटेगरी के लिए बिड के साथ वैध समर्थित दस्तावेज़ प्रस्तुत करने हैं। एमएसई केटेगरी के अंतर्गत केवल वस्तुओं के लिए विनिर्माता तथा सेवाओं के लिए सेवा प्रदाता ईएमडी से छूट के पात्र हैं। व्यापारियों को इस नीति के दायरे से बाहर रखा गया है।

(b). EMD & Performance security should be in favour of Beneficiary, wherever it is applicable./ईएमडी और संपादन जमानत राशि, जहां यह लागू होती है, लाभार्थी के पक्ष में होनी चाहिए।

Beneficiary/लाभार्थी :

(Nhpc Limited)
NHPC Office Complex, Sector-33, Faridabad, Haryana-121003
(Nhpc Limited)

Splitting/विभाजन

Bid splitting not applied/बोली विभाजन लागू नहीं किया गया.

MII Purchase Preference/एमआईआई खरीद वरीयता

MII Purchase Preference/एमआईआई खरीद वरीयता	Yes
--	-----

MSE Purchase Preference/एमएसई खरीद वरीयता

MSE Purchase Preference/एमएसई खरीद वरीयता	Yes
---	-----

1. If the bidder is a Micro or Small Enterprise as per latest definitions under MSME rules, the bidder shall be exempted from the requirement of "Bidder Turnover" criteria and "Experience Criteria" subject to meeting of quality and technical specifications. If the bidder is OEM of the offered products, it would be exempted from the "OEM Average Turnover" criteria also subject to meeting of quality and technical specifications. In case any bidder is seeking exemption from Turnover / Experience Criteria, the supporting documents to prove his eligibility for exemption must be uploaded for evaluation by the buyer.
2. If the bidder is a Startup, the bidder shall be exempted from the requirement of "Bidder Turnover" criteria and "Experience Criteria" subject to their meeting of quality and technical specifications. If the bidder is OEM of the offered products, it would be exempted from the "OEM Average Turnover" criteria also subject to meeting of quality and technical specifications. In case any bidder is seeking exemption from Turnover / Experience Criteria, the supporting documents to prove his eligibility for exemption must be uploaded for evaluation by the buyer.
3. The minimum average annual financial turnover of the bidder during the last three years, ending on 31st March of the previous financial year, should be as indicated above in the bid document. Documentary evidence in the form of certified Audited Balance Sheets of relevant periods or a certificate from the Chartered Accountant / Cost Accountant indicating the turnover details for the relevant period shall be uploaded with the bid. In case the date of constitution / incorporation of the bidder is less than 3-year-old, the average turnover in respect of the completed financial years after the date of constitution shall be taken into account for this criteria.
4. Experience Criteria: In respect of the filter applied for experience criteria, the Bidder or its OEM {themselves or through reseller(s)} should have regularly, manufactured and supplied same or similar Category Products to any Central / State Govt Organization / PSU / Public Listed Company for number of Financial years as indicated above in the bid document before the bid opening date. Copies of relevant contracts to be submitted along with bid in support of having supplied some quantity during each of the Financial year. In case of bunch bids, the category of primary product having highest value should meet this criterion.
5. OEM Turn Over Criteria: The minimum average annual financial turnover of the OEM of the offered product during the last three years, ending on 31st March of the previous financial year, should be as indicated in the bid document. Documentary evidence in the form of certified Audited Balance Sheets of relevant periods or a certificate from the Chartered Accountant / Cost Accountant indicating the turnover details for the relevant period shall be uploaded with the bid. In case the date of constitution / incorporation of the OEM is less than 3 year old, the average turnover in respect of the completed financial years after the date of constitution shall be taken into account for this criteria.
6. Preference to Make In India products (For bids < 200 Crore):Preference shall be given to Class 1 local supplier as defined in public procurement (Preference to Make in India), Order 2017 as amended from time to time and its subsequent Orders/Notifications issued by concerned Nodal Ministry for specific Goods/Products. The minimum local content to qualify as a Class 1 local supplier is denoted in the bid document. If the bidder wants to avail the Purchase preference, the bidder must upload a certificate from the OEM regarding the percentage of the local content and the details of locations at which the local value addition is made along with their bid, failing which no purchase preference shall be granted. In case the bid value is more than Rs 10 Crore, the declaration relating to percentage of local content shall be certified by the statutory auditor or cost auditor, if the OEM is a company and by a practicing cost accountant or a chartered accountant for OEMs other than companies as per the Public Procurement (preference to Make-in -India) order 2017 dated 04.06.2020. Only Class-I and Class-II Local suppliers as per MII order dated 4.6.2020 will be eligible to bid. Non - Local suppliers as per MII order dated 04.06.2020 are not eligible to participate. However, eligible micro and small enterprises will be allowed to participate .The buyers are advised to refer the OM No.F.1/4/2021-PPD dated 18.05.2023.
[OM No.1_4_2021_PPD_dated_18.05.2023](#) for compliance of Concurrent application of Public Procurement Policy for Micro and Small Enterprises Order, 2012 and Public Procurement (Preference to Make in India) Order, 2017.

7. Purchase preference to Micro and Small Enterprises (MSEs): Purchase preference will be given to MSEs as defined in Public Procurement Policy for Micro and Small Enterprises (MSEs) Order, 2012 dated 23.03.2012 issued

by Ministry of Micro, Small and Medium Enterprises and its subsequent Orders/Notifications issued by concerned Ministry. If the bidder wants to avail the Purchase preference, the bidder must be the manufacturer of the offered product in case of bid for supply of goods. Traders are excluded from the purview of Public Procurement Policy for Micro and Small Enterprises. In respect of bid for Services, the bidder must be the Service provider of the offered Service. Relevant documentary evidence in this regard shall be uploaded along with the bid in respect of the offered product or service. If L-1 is not an MSE and MSE Seller (s) has/have quoted price within L-1+ 15% (Selected by Buyer)of margin of purchase preference /price band defined in relevant policy, such Seller shall be given opportunity to match L-1 price and contract will be awarded for 25%(selected by Buyer) percentage of total QUANTITY.The buyers are advised to refer the OM No.F.1/4/2021-PPD dated 18.05.2023

[OM No.1 4 2021 PPD dated 18.05.2023](#) for compliance of Concurrent application of Public Procurement Policy for Micro and Small Enterprises Order, 2012 and Public Procurement (Preference to Make in India) Order, 2017.

8. Estimated Bid Value indicated above is being declared solely for the purpose of guidance on EMD amount and for determining the Eligibility Criteria related to Turn Over, Past Performance and Project / Past Experience etc. This has no relevance or bearing on the price to be quoted by the bidders and is also not going to have any impact on bid participation. Also this is not going to be used as a criteria in determining reasonableness of quoted prices which would be determined by the buyer based on its own assessment of reasonableness and based on competitive prices received in Bid / RA process.

9. Past Performance: The Bidder or its OEM {themselves or through re-seller(s)} should have supplied same or similar Category Products for 50% of bid quantity, in at least one of the last three Financial years before the bid opening date to any Central / State Govt Organization / PSU / Public Listed Company. Copies of relevant contracts (proving supply of cumulative order quantity in any one financial year) to be submitted along with bid in support of quantity supplied in the relevant Financial year. In case of bunch bids, the category related to primary product having highest bid value should meet this criterion.

High Mast Lighting Tower For Large Area With LED Flood Lighting System (2 pieces)

(Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively/क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक)

Technical Specifications/तकनीकी विशिष्टियाँ

* As per GeM Category Specification/जेम केटेगरी विशिष्टि के अनुसार

Specification	Specification Name/विशिष्टि का नाम	Bid Requirement/बिड के लिए आवश्यक (Allowed Values)/अनुमत मूल्य
GENERIC	Height of High Mast Tower (in Meters)	20
	Installation and commissioning (Installation and commissioning work at multiple locations shall follow as per the guidelines of State/Central Govt rules and regulations as applicable)	Yes. Including Civil work at site
	Onsite warranty (in Years)	2
High mast System	No of sections	2
	Effective length of each section (in m)	10, 10.5, 8.5, 5
	Material construction: The mast shall be manufactured using special steel plates, conforming to	355 grade as per BSEN10 025
	Bottom diameter (in mm) - Minimum	540

Specification	Specification Name/विशिष्टि का नाम	Bid Requirement/बिड के लिए आवश्यक (Allowed Values)/अनुमत मूल्य
	Plate thickness for Middle (in mm) - Minimum	4
	Plate thickness for Bottom (in mm) - Minimum	5
	No of longitudinal welds / section (in Nos)	1, 2
	Diameter of base plate (in mm) - Minimum	740
	Thickness of base plate (in mm) - Minimum	30
Wind Load	Maximum Wind load	50 m/sec
Door Opening	Size of opening and closing door at base compartment of high mast (in mm) - Minimum	1200 x 250
Junction Box	Ingress protection for Junction Box i.e. IP Class (as per IS/IEC:60529:2001 latest) Test Report from Central Government lab/NABL/ILAC accredited lab and report shall furnish to buyer on demand	IP 55
	No of core	3, 4, 5
	Cable category	FR-LSH
	Size of cable (in Sq mm)	1.5
	Conductor material shall be	Copper
Winch	The winch shall have provision for manual operation in case of failure of the motor	Yes
Stainless Steel Wire Rope	The breaking load of each rope shall be at full load as per the relevant standard	>/=2400 Kg
Electrical System, Cable and Cable Connections	No. of cores	3
	Cable shall be	Unarmoured
	Conductor material shall be	Copper
	Cable Category	1
	Incoming power cable from feeder panel to base compartment of mast and cable shall conforming to	IS:7098 (Part 1):1988 latest
Feeder pillar Panel	Feeder pillar panel for each mast	Yes

Specification	Specification Name/विशिष्टि का नाम	Bid Requirement/बिड के लिए आवश्यक (Allowed Values)/अनुमत मूल्य
	Feeder panel shall be suitable for	415 V, 3 phase, 4 wire, 50 Hz, AC
	The control panels shall be	Stand mounted
	Ingress protection for feeder pillar panel i.e IP Class (as per IS/IEC:60529:2001 latest). Test Report shall furnish from Central Government lab/NABL/ILAC accredited lab to buyer on demand	IP 55
	It shall be fabricated out of	14 SWG CRCA sheet steel
	Thickness of sheet (in mm)	2
	The panels shall be given pre-treatment and powder coated and color shall be	Grey
	The stand shall be painted in	Black color
	Cable entry shall be at the	Bottom
	The panels shall have	knock outs of the required cable
	Laminated circuit diagram shall be pasted	inside of the door
	Feeder pillar shall have pad locking arrangement	Yes
	Earth terminal	12 mm dia. Bolts
	Panel shall have a sloping cover to avoid accumulation of dust	Yes
	Panel shall be provided with incoming & outgoing MCCB / MCB of appropriate rating and in desired quantity depending on total no of circuits in use	yes
	Timer for automatic ON & OFF of lights with pilot lamps shall be provided	Yes
	Bus bars material	Yes. Copper
	No of Cores	3
	Size of cable (in Sq.mm)	1.5
	Cable Shall be	Unarmoured
	The conductor material shall be	Copper

Specification	Specification Name/विशिष्टि का नाम	Bid Requirement/बिड के लिए आवश्यक (Allowed Values)/अनुमत मूल्य
	cable category	1
LED FLOOD LIGHT LUMINAIRE	No. of Luminaires for each high mast lighting tower (in Nos)	12
	LED Rating/System Wattage/Rated Power for each luminaire	350W
	Luminaire System Efficacy (Lumen/watt)	>/= 100 Lm/Watt
	Ingress Protection (IP Rating) as per IS:10322 (Part 1):1982 latest	IP65
	Mounting brackets (included)	Adjustable
	Input operating Voltage range and frequency	90 to 300 Volts AC at 50Hz+/-2Hz
	Rated voltage	230 V AC 50 Hz
	Colour temperature	6000K (+/- 500K)
	Optic lense material (UV stabilised) (Write NA for without optic lense supply)	Poly carbonate lense
	Operating temperature range	-20 deg C to +50 deg C
	The luminaire shall be protected against surges and transients(Internal)	>/=5KV
	Extruded silicon loop gasket shall be provided in the lantern body to ensure a weather proof seal between the UV Glass cover and the metal housing to exclude the entry of the dust,water,insects etc	Yes
	Number of electronic control gear per luminaire (power supplies)	1 No.
	Length of ISI marked three core wire (shall be provided along with supply of material)	50 cm

Additional Specification Parameters - High Mast Lighting Tower For Large Area With LED Flood Lighting System (2 pieces)

Specification Parameter Name	Bid Requirement (Allowed Values)
ANALYSIS & DESIGN, MATERIAL OF MAST	Analysis and Design based upon ILE TR7,Material of the mast conform to IS:2062,The mast sections shall be hot dip galvanized to minimum 80 microns both inside and outside, AVIATION OBSTRUCTION WARNING LIGHTS & LIGHTNING ARRESTOR,Foundation of high mast shall be suitable for Zone V, Construction of shallow foundation with 1:2:4 concrete of the High Mast considering safe soil bearing capacity at site as 10 T/m2 at 2 mtr depth,Earthing with 3mtr, 50mm dia electrode with 25X3 mm GI flats
LANTERN CARRIAGE, WINCH ASSEMBLY, MOTOR AND ROPE	Lantern carriage assembly shall be as per IS:4759/BSEN1461min thickness of 80 microns,Winch assembly shall be a double winch,Lantern carriage shall be operated with a three-point (three ropes) system for preventing wobbling of the carriage during raising and lowering & operation as per "Dead man principle",The electric motor min. rating shall be 3HP,Make-Crompton Greaves/Kirloskar/Siemens/Bharat Bijlee/ABB,Wire ropes shall be flexible marine grade&non corrosive stainlesssteel grade SS316
CONTROL PANEL, LUMINAIRES, FINIAL, WIRES & CABLES	1TPN 63 A for I/c, 1 MCB 32 A 3P for motor &3 nos 2P MCB for Luminaries,All MCBs and Contractor, Timer make shall be Legrand/Simens/GE/Havells/ Schneider/ABB,LED flood light with innovatove Aluminium Die cast body,lighting design from Dialux software. LM 79 report & LM 80 report of the original chip manufacturer justifying L70 @ 50000 Hrs shall be submitted along with the bid,Internal wiring from 2.5sqmm Copper wire, external wiring from 5 core, 4sqmm flexible Copper Cables only

* Bidders offering must also comply with the additional specification parameters mentioned above.

Installation Commissioning and Testing (ICT) details for the above item:

% of Product Cost Payable on Product Delivery	70%
Min Cost Allocation for ICT as a % of product cost	30%
Number of days allowed for ICT after site readiness communication to seller	30 Days/दिन

Consignees/Reporting Officer/परेषिती/रिपोर्टिंग अधिकारी and/ तथा Quantity/मात्रा

S.No./क्र. सं.	Consignee Reporting/Officer/ परेषिती/रिपोर्टिंग अधिकारी	Address/पता	Quantity/मात्रा	Delivery Days/डिलीवरी के दिन
1	Niranjan Singh	792110,Mayu, Roing, Dibang Multi Purpose Project, NHPC Limited	2	30

Buyer Added Bid Specific Terms and Conditions/क्रेता द्वारा जोड़ी गई बिड की विशेष शर्तें

1. Inspection

Pre-dispatch inspection at Seller premises (Fee/Charges to be borne by the BUYER): Before dispatch, the goods will be inspected by Buyer / Consignee or their Authorized Representative or by Nominated External Inspection Agency (independently or jointly with Buyer or Consignee as decided by the Buyer) at Seller premises (or at designated place for inspection as declared / communicated by the seller) for their compliance to the contract specifications. Fee/Charges taken by the External inspection Agency and any external laboratories testing charges shall be borne by the Buyer. For in-house testing, the Sellers will provide necessary facilities free of cost. Seller shall notify the Buyer through e-mail about readiness of goods for pre-dispatch inspection and Buyer will notify the Seller about the Authorized Representative/ Nominated External Inspection Agency and the date for testing. The goods would be dispatched to consignee only after clearance in pre-dispatch inspection. Consignee's right of rejection as per GTC in respect of the goods finally received at his location shall in no way be limited or waived by reason of the goods having previously been inspected, tested and passed by Buyer/ Consignee or its Nominated External Inspection Agency prior to the goods' shipment. While bidding, the sellers should take into account 7 days for inspection from the date of email offering the goods for inspection. Any delay in inspection beyond 7 days shall be on the part of the buyer and shall be regularised without Liquidated Damages.

When there is requirement of submission the advance sample, the seller shall inform the buyer promptly through emails about the date of submission of sample to the buyer nominated Inspection agency.

2. **Forms of EMD and PBG**

Bidders can also submit the EMD with Account Payee Demand Draft in favour of

NHPC Limited
payable at
payable at SBI, Roing, (Branch Code 05821)

.
Bidder has to upload scanned copy / proof of the DD along with bid and has to ensure delivery of hardcopy to the Buyer within 5 days of Bid End date / Bid Opening date.

3. **Forms of EMD and PBG**

Bidders can also submit the EMD with Banker's Cheque in favour of

NHPC Limited
payable at
payable at SBI, Roing, (Branch Code 05821)

.
Bidder has to upload scanned copy / proof of the BC along with bid and has to ensure delivery of hardcopy to the Buyer within 5 days of Bid End date / Bid Opening date.

4. **Forms of EMD and PBG**

Successful Bidder can submit the Performance Security in the form of Account Payee Demand Draft also (besides PBG which is allowed as per GeM GTC). DD should be made in favour of

NHPC Limited
payable at
payable at SBI, Roing, (Branch Code 05821)

. After award of contract, Successful Bidder can upload scanned copy of the DD in place of PBG and has to ensure delivery of hard copy to the original DD to the Buyer within 15 days of award of contract.

5. **Scope of Supply**

Scope of supply (Bid price to include all cost components) : Supply Installation Testing and Commissioning of Goods

6. **Generic**

Buyer Organization specific Integrity Pact shall have to be complied by all bidders. Bidders shall have to upload scanned copy of signed integrity pact as per Buyer organizations policy along with bid. [Click here to view the file](#)

7. **Buyer Added Bid Specific ATC**

Buyer Added text based ATC clauses

1. If the Seller fails to submit duly filled & signed copy of the Buyer Organization Specific Integrity Pact along with the bid, the bid of such Seller shall be liable to be rejected.
2. The successful bidder shall submit design drawing and program of performance considering the specific technical parameters for approval of EIC.

Disclaimer/अस्वीकरण

The additional terms and conditions have been incorporated by the Buyer after approval of the Competent Authority in Buyer Organization, whereby Buyer organization is solely responsible for the impact of these clauses on the bidding process, its outcome, and consequences thereof including any eccentricity / restriction arising in the bidding process due to these ATCs and due to modification of technical specifications and / or terms and conditions governing the bid. Any clause(s) incorporated by the Buyer regarding following shall be treated as null and void and would not be considered as part of bid:-

1. Definition of Class I and Class II suppliers in the bid not in line with the extant Order / Office Memorandum issued by DPIIT in this regard.
2. Seeking EMD submission from bidder(s), including via Additional Terms & Conditions, in contravention to exemption provided to such sellers under GeM GTC.
3. Publishing Custom / BOQ bids for items for which regular GeM categories are available without any Category item bunched with it.
4. Creating BoQ bid for single item.
5. Mentioning specific Brand or Make or Model or Manufacturer or Dealer name.
6. Mandating submission of documents in physical form as a pre-requisite to qualify bidders.
7. Floating / creation of work contracts as Custom Bids in Services.
8. Seeking sample with bid or approval of samples during bid evaluation process.
9. Mandating foreign / international certifications even in case of existence of Indian Standards without specifying equivalent Indian Certification / standards.
10. Seeking experience from specific organization / department / institute only or from foreign / export experience.
11. Creating bid for items from irrelevant categories.
12. Incorporating any clause against the MSME policy and Preference to Make in India Policy.
13. Reference of conditions published on any external site or reference to external documents/clauses.
14. Asking for any Tender fee / Bid Participation fee / Auction fee in case of Bids / Forward Auction, as the case may be.

Further, if any seller has any objection/grievance against these additional clauses or otherwise on any aspect of this bid, they can raise their representation against the same by using the Representation window provided in the bid details field in Seller dashboard after logging in as a seller within 4 days of bid publication on GeM. Buyer is duty bound to reply to all such representations and would not be allowed to open bids if he fails to reply to such representations.

[This Bid is also governed by the General Terms and Conditions/ यह बिड सामान्य शर्तों के अंतर्गत भी शासित है](#)

In terms of GeM GTC clause 26 regarding Restrictions on procurement from a bidder of a country which shares a land border with India, any bidder from a country which shares a land border with India will be eligible to bid in this tender only if the bidder is registered with the Competent Authority. While participating in bid, Bidder has to undertake compliance of this and any false declaration and non-compliance of this would be a ground for immediate termination of the contract and further legal action in accordance with the laws./जेम की सामान्य शर्तों के खंड 26 के संदर्भ में भारत के साथ भूमि सीमा साझा करने वाले देश के बिडर से खरीद पर प्रतिबंध के संबंध में भारत के साथ भूमि सीमा साझा करने वाले देश का कोई भी बिडर इस निविदा में बिड देने के लिए तभी पात्र होगा जब वह बिड देने वाला सक्षम प्राधिकारी के पास पंजीकृत हो। बिड में भाग लेते समय बिडर को इसका अनुपालन करना होगा और कोई भी गलत घोषणा किए जाने व इसका अनुपालन न करने पर अनुबंध को तत्काल समाप्त करने और कानून के अनुसार आगे की कानूनी कार्यवाई का आधार होगा।

---Thank You/धन्यवाद---