

NHPC LIMITED
(A Govt. of India Enterprise)
CIN: L40101HR1975GOI032564

CORRIGENDUM NO.1



Name of the Work	:	Package-6, Modification of Diversion Tunnel into Tunnel Spillway Arrangement - Civil & HM Works (Tunnel Spillway, Adit to GOC, GOC Gate Shaft, Inlet Bellmouth, Outlet Concrete Dyke and Energy Dissipation Arrangement) for Teesta-V Power Station, Sikkim
Tender ID No.	:	2024_NHPC_812702_1
Tender Specification No.	:	NH/CCW/CC-II/CO-323/PR-11124/47
Corrigendum Date	:	03-07-2024

Sr. No.	Bid Condition	Amendment
Section-I, NIT		
1.	Clause-1 , sl. no. (vi) of critical dates of tender: Online Bid Submission closing Date & Time : 08.07.2024 (15:00 Hrs)	Online Bid Submission closing Date & Time : 18.07.2024 (15:00 Hrs)
2.	Clause-1 , sl. no. (viii) of critical dates of tender: Online Bid Opening of Technical Bid (Cover-I) Date & Time : 09.07.2024 (15:30 Hrs)	Online Bid Opening of Technical Bid (Cover-I) Date & Time : 19.07.2024 (15:30 Hrs)

NHPC LIMITED
(A Govt. of India Enterprise)
CIN: L40101HR1975GOI032564

CORRIGENDUM NO.1



Sr. No.	Bid Condition	Amendment
Bidding Data:		
3.	Sl. no. 6: Deadline for Online Submission of Bids : Date : 08.07.2024 Time : 15:00 Hrs	Deadline for Online Submission of Bids : Date : 18.07.2024 Time : 15:00 Hrs
4.	Sl. no. 8: Time and Date for opening of Technical Bid / Bids : Date : 09.07.2024 Time : 15:30 Hrs	Time and Date for opening of Technical Bid / Bids : Date : 19.07.2024 Time : 15:30 Hrs
Section-VI: PTS		

NHPC LIMITED
(A Govt. of India Enterprise)
CIN: L40101HR1975GOI032564

CORRIGENDUM NO.1



Sr. No.	Bid Condition	Amendment
5.	<p>PTS Clause 2.3</p> <p>Hydraulic hoist and power pack:</p> <p>.....</p> <p>The ceramic coating on piston rod shall be designed to rule out corrosion of piston rod. It shall be homogenous, scratch resistant, free of cracks.</p> <p>.....</p>	<p>Hydraulic hoist and power pack:</p> <p>.....</p> <p>The chrome plating on piston rod shall be designed to rule out corrosion of piston rod. It shall be homogenous, scratch resistant and free of cracks.</p> <p>.....</p>
6.	<p>PTS Clause 4.1.2</p> <p>Ecological/Environmental flow gate</p>	<p>Following new para has been added after 2nd para of PTS Clause 4.1.2 “Ecological/Environmental flow gate”:</p> <p>The discharge through Ecological/ Environmental flow gate shall be measured with the help of suitable flow measurement device and shall be displayed in the Dam control room. The system shall also be provided with a compatible data logger unit to record and transmit the discharge data to a remote location on real time basis using internet interfaces. The details and location etc. shall be finalized during detailed engineering stage.</p>
7.	<p>Attachment 5 – Item no. 2 & 3</p> <p>Hydraulic cylinder & Hydraulic power pack:</p>	<p>Hydraulic cylinder & Hydraulic power pack:</p>

NHPC LIMITED
(A Govt. of India Enterprise)
CIN: L40101HR1975GOI032564

CORRIGENDUM NO.1



Sr. No.	Bid Condition	Amendment
	Approved List of Subcontractors / Vendors - VHT (BV)	Approved List of Subcontractors / Vendors- VHT

All other provisions / terms and conditions of the Bid document shall remain unchanged.

General Manager (CC-II),
E-mail: contcivil2-co@nhpc.nic.in