



एनएचपीसी लिमिटेड
NHPC LIMITED
(भारत सरकार का उद्यम)
(A Govt. of India Enterprise)
तीस्ता V पावर स्टेशन
Teesta V Power Station
सिंगतम, पूर्वी सिक्किम - 737134
Singtam, East Sikkim- 737134



IS/ISO 9001 IS/ISO 14001 IS 18001
आई एम एस प्रमाणित पावर स्टेशन
IMS certified Power Station
दूरभाष/Ph: 03592-247349
फैक्स/Fax: 03592-247227/349

NH/TSV/Cont/CC-323/NIT-977/2024-25/ 373

Dated: 13-12-2024

Corrigendum-I

Please refer to Tender invited vide NIT No.: **NH/TSV/Cont/CC-323/NIT-977/2024-25/351**
Dated: 27/11/2024 (Tender ID: **2024_NHPC_836732_1**) for the work of "Supplying, Erection, Testing and Commissioning of Electrical & Mechanical works and construction of Civil works for 90 KLD sewage treatment plant (STP) for NHPC Teesta V Right Bank Colony, Balutar" in which following amendments are hereby made in referred NIT:


1. Critical dates of the tender has been extended as under:

1	Online Bid Submission closing (Date & Time)	24.12.2024 (17:30 Hrs)
2	Offline Bid Submission closing (Date & Time)	27.12.2024 (16:30 Hrs)
3	Online Bid Opening (Cover-I) (Date & Time)	30.12.2024 (16:00 Hrs)

2. Further, the final consolidated Reply of employer (NHPC Ltd.) on Techno-Commercial queries (from the prospective bidder) has been attached herewith as Annexure-A (Reply of Techno-Commercial queries).

All other terms & conditions of Tender Documents shall remain unchanged.

For & On behalf of NHPC Limited.


Dy. General Manager (Civil)
Contract Division
Teesta – V Power Station



एनएचपीसी लिमिटेड
NHPC LIMITED
 (भारत सरकार का उद्यम)
 (A Govt. of India Enterprise)
 तीस्ता V पावर स्टेशन
Teesta V Power Station
 सिंगतम, पूर्वी सिक्किम - 737134
 Singtam, East Sikkim- 737134

IS/ISO 9001 IS/ISO 14001 IS 18001
 आई एम एस प्रमाणित पावर स्टेशन
 IMS certified Power Station
 दूरभाष/Ph: 03592-247349
 फ़ैक्स/Fax: 03592-247227/349

Annexure-A

Final consolidated Reply of employer (NHPC Ltd.) on Techno-Commercial queries (from the prospective bidders)

Sl No.	Clause	Query	Reply
1]	BOQ PAGE 235 and 236 OF TENDER FILE [clause sr. no. of table 10, 15 and 19]	Chlorination UV and Ozonation all three are provided to be quoted and installed as per tender. I would like the team to assess the technical design as all the three application is for disinfection colour and Odor removal. If we are going with Chlorination and Ozonation we should not go for UV. [Please provide us clarity whether we should bid for all three items as stated in BOQ]	1.) Chlorination UV and Ozonation all three are provided to be quoted and installed as per tender- YES 2.) ALL these three is for disinfection colour and Odour removal and also BOD removal. 3.) Chlorination is also as a part of tertiary treatment unit apart from others. Bid required for all three items as per BOQ.
2]	BOQ PAGE 236 OF TENDER FILE [clause sr. no. of table 20]	Sizing of the MSEP Tanks required in details and thickness of tanks.) Sizing of the MSEP Tanks is Mentioned in Attached Drawing AT CP# 25-27, Ref:- Drawing of tender page no.# 239-242) Thickness of MSEP tanks= Min 05 mm th Ref:- Drawing of tender page no.# 239 - 242
3]	Payment Terms	Please define payment terms as NOT CLEARLY STATED IN Section 4 GCC	Payment Terms:- AS per SCC clause no. 23 Contractor has to submit Professional Tax clearance certificate from Commercial Tax Department, Govt. of Sikkim" along with RA Bill in conjunction to CLAUSE-45 : PAYMENT ON ACCOUNT of GCC Section – IV (Ref:- Tender page no.# 143