



A Navratna Company

एनएचपीसी लिमिटेड

NHPC LIMITED

(भारत सरकार का उद्यम)

(A Govt. of India Enterprise)

तीस्ता V पावर स्टेशन

Teesta V Power Station

सिंगतम, पूर्वी सिक्किम - 737134

Singtam, East Sikkim- 737134



IS/ISO 9001 IS/ISO 14001 IS 18001

आई एम एस प्रमाणित पावर स्टेशन

IMS certified Power Station

दूरभाष/Ph: 03592-247349

फैक्स/Fax: 03592-247227/349

Ref No. NH/TSV/Cont/MC-154/NIT-1004/2025-26/03

Dated: 04-04-2025

Corrigendum-I

Please refer to Tender invited vide NIT No.: NH/TSV/CONT/MC-154/NIT-1004/2024-25/502 Dated: 24/03/2025 (Tender ID: 2025_NHPC_854268_1) for the work of "Design, Fabrication/Manufacturing, Supply, Transportation, Erection and Commissioning of 03 Nos. of TRT gates along with electrically operated 50T capacity Rope Drum Hoist" in which following amendments are hereby made in referred NIT:

1. Technical corrigendum has been made at Clause No. 2.0 of PTS (Particular Technical Specification) of Section-VIII of Tender documents for inclusion of '**Lifting/Lowering speed of Gate: 0.5 m/min (minimum)**' under Main data. (Details are as per Annexure-A attached herewith).

Further, the final consolidated Reply of employer (NHPC Ltd.) on Techno-Commercial queries (from the prospective bidders (received through emails & pre-bid meeting held on 01.04.2025)) has been attached herewith as Annexure-B (Reply of Techno-Commercial queries).

There will be no change in bid submission (Online & Offline) date & time.

All other terms & conditions of Tender Documents shall remain unchanged.

For & On behalf of NHPC Limited.

Dy. General Manager (Elect.)

Contract Division

Teesta - V Power Station



A Navratna Company

एनएचपीसी लिमिटेड

NHPC LIMITED

(भारत सरकार का उद्यम)

(A Govt. of India Enterprise)

तीस्ता V पावर स्टेशन

Teesta V Power Station

सिंगतम, पूर्वी सिक्किम - 737134

Singtam, East Sikkim- 737134



IS/ISO 9001 IS/ISO 14001 IS 18001

आई एम एस प्रमाणित पावर स्टेशन

IMS certified Power Station

दूरभाष/Ph: 03592-247349

फ़ैक्स/Fax: 03592-247227/349

Annexure-A

The following clause of tender document under reference are hereby modified and shall be read as follows:

Sl. No.	Clause No.	As per tender document	After Amendment
1.	Clause No. 2.0 of PTS (Particular Technical Specification) of Section-VIII of Tender documents	<p>2.0 TRT GATE & ROPE DRUM HOIST</p> <p>TRT GATE</p> <p>To isolate tunnel/generating unit (turbines) from the tail water to cater to the inspection/maintenance requirement of turbines.....exceeding 80% of yield point of materials.</p> <p>The Rope drum hoist shall be equipped with.....access ladders and walkways.</p> <p>Interlocking: Suitable interlocking will be provided between tailrace tunnel gates & turbines to disallow the turbine operation till the gates are in fully open condition.</p>	<p>2.0 TRT GATE & ROPE DRUM HOIST</p> <p>TRT GATE</p> <p>To isolate tunnel/generating unit (turbines) from the tail water to cater to the inspection/maintenance requirement of turbines.....exceeding 80% of yield point of materials.</p> <p>The Rope drum hoist shall be equipped with.....access ladders and walkways.</p> <p>Interlocking: Suitable interlocking will be provided between tailrace tunnel gates & turbines to disallow the turbine operation till the gates are in fully open condition.</p>

Corporate Office: NHPC Limited, NHPC Office Complex, Sector-33, Faridabad-121003 (Haryana)

निगम मुख्यालय एन.एच.पी.सी. लिमिटेड :, एनएचपीसी ऑफिस कॉम्प्लेक्स, सेक्टर-33, फरीदाबाद-121003(हरियाणा)

Corporate Identification Number (CIN): L40101HR1975GOI032564

Handwritten signature



A Navratna Company

एनएचपीसी लिमिटेड

NHPC LIMITED

(भारत सरकार का उद्यम)

(A Govt. of India Enterprise)

तीस्ता V पावर स्टेशन

Teesta V Power Station

सिंगतम, पूर्वी सिक्किम - 737134

Singtam, East Sikkim- 737134



IS/ISO 9001 IS/ISO 14001 IS 18001

आई एम एस प्रमाणित पावर स्टेशन

IMS certified Power Station

दूरभाष/Ph: 03592-247349

फैक्स/Fax: 03592-247227/349

		<p>MAIN DATA</p> <p>Number of tailrace gate :03 Nos</p> <p>Type :Fixed wheel type</p> <p>Operation Lowering under unbalanced head Raising under balanced head conditions after crack opening 150mm</p> <p>Clear width of opening :5:40m</p> <p>Clear height of opening :5:52m</p> <p>Sill elevation :EL. 359.00M</p> <p>Max TWL :EL. 379.00M</p> <p>Design head :20.00m</p>	<p>MAIN DATA</p> <p>Number of tailrace gate :03 Nos</p> <p>Type :Fixed wheel type</p> <p>Operation Lowering under unbalanced head Raising under balanced head conditions after crack opening 150mm</p> <p>Clear width of opening :5:40m</p> <p>Clear height of opening :5:52m</p> <p>Sill elevation :EL. 359.00M</p> <p><u>Lifting/Lowering speed : 0.5 m/min (minimum) of Gate</u></p> <p>Max TWL :EL. 379.00M</p> <p>Design head :20.00m</p>
--	--	--	--

Handwritten signature

Corporate Office: NHPC Limited, NHPC Office Complex, Sector-33, Faridabad-121003 (Haryana)

निगम मुख्यालय एन.एच.पी.सी. लिमिटेड :, एनएचपीसी ऑफिस कॉम्प्लेक्स, सेक्टर-33, फरीदाबाद-121003(हरियाणा)

Corporate Identification Number (CIN): L40101HR1975GOI032564



A Navratna Company

एनएचपीसी लिमिटेड

NHPC LIMITED

(भारत सरकार का उद्यम)

(A Govt. of India Enterprise)

तीस्ता V पावर स्टेशन

Teesta V Power Station

सिंगतम, पूर्वी सिक्किम - 737134

Singtam, East Sikkim- 737134



IS/ISO 9001 IS/ISO 14001 IS 18001

आई एम एस प्रमाणित पावर स्टेशन

IMS certified Power Station

दूरभाष/Ph: 03592-247349

फैक्स/Fax: 03592-247227/349

Annexure-B

Final consolidated Reply of Employer (NHPC Ltd.) on Techno-Commercial queries (from the prospective bidders through emails and Pre-bid meeting held on 01.04.2025)

SL. N.	Tender Reference	Tender Description	Pre-Bid query (Techno-Commercial) received	Reply of NHPC LTD.
1	Clause No. 22.3 of ITB (Section-II of tender documents)	<p>e-Reverse Auction (e-RA)</p> <p>22.3.1 e-RA shall be followed after e-tender only if number of eligible bidders at price bid stage are at least 2 (two). Following Procedure shall be followed for e-RA:</p> <p>a. If the discovered price is upto 105% of the estimated cost, no e-RA will be conducted.</p> <p>b. If the discovered price is above the price mentioned in (a) above, then following procedure of e-RA shall be followed:</p> <ul style="list-style-type: none"> In case the number of eligible Bidders is 3 or less than 3, then e-RA shall be conducted among all the bidders. 	<p>There is a provision of e-Reverse Auction in the tender document. Reverse auctions are widely used in procurement only tenders to drive down costs. This particular work is a highly specialized job and involves manufacturing of precision equipments with highly skilled engineering techniques. We have identified several disadvantages associated with this reverse auction method, which could badly impact the quality of the deliverables and the long-term value of the contract.</p>	No change.

Corporate Office: NHPC Limited, NHPC Office Complex, Sector-33, Faridabad-121003 (Haryana)
 निगम मुख्यालय एन.एच.पी.सी. लिमिटेड :, एनएचपीसी ऑफिस कॉम्प्लेक्स, सेक्टर-33, फरीदाबाद-121003(हरियाणा)
 Corporate Identification Number (CIN): L40101HR1975GOI032564

Handwritten signature



A Navratna Company

एनएचपीसी लिमिटेड
NHPC LIMITED

(भारत सरकार का उद्यम)
(A Govt. of India Enterprise)
तीस्ता V पावर स्टेशन

Teesta V Power Station
सिंगतम, पूर्वी सिक्किम - 737134
Singtam, East Sikkim- 737134



IS/ISO 9001 IS/ISO 14001 IS 18001
आई एम एस प्रमाणित पावर स्टेशन
IMS certified Power Station
दूरभाष/Ph: 03592-247349
फैक्स/Fax: 03592-247227/349

		<ul style="list-style-type: none"> In case the number of eligible Bidders are 4, then e-RA shall be conducted among the bidders except H1. In case the number of eligible Bidders are more than 4, then the bidders quoting higher rates shall be eliminated as per below formula, and e-RA shall be conducted among the remaining bidders: <p>Numbers of eliminated bidders = $(n-3) \times 0.5$ where n = total bidders</p> <p>(In case "Numbers of eliminated bidders" is a fraction, it shall be rounded off to lower whole number.)</p>		
2	Section-VIII of Tender Documents (Technical	Clause no. 2 of PTS (Particular Technical Specification) of Section-VIII of Tender documents	After going through the technical specification of 50 T Capacity rope drum hoist of TRT Gate for Teesta-V H.E. Project(510 MW), we would like to bring under kind notice that	The lifting/lowering speed of the Rope Drum Hoist should not less than 0.5

Corporate Office: NHPC Limited, NHPC Office Complex, Sector-33, Faridabad-121003 (Haryana)
निगम मुख्यालय एन.एच.पी.सी. लिमिटेड :, एनएचपीसी ऑफिस कॉम्प्लेक्स, सेक्टर-33, फरीदाबाद-121003(हरियाणा)
Corporate Identification Number (CIN): L40101HR1975GOI032564

Handwritten signature



A Navratna Company

एनएचपीसी लिमिटेड
NHPC LIMITED

(भारत सरकार का उद्यम)
(A Govt. of India Enterprise)
तीस्ता V पावर स्टेशन

Teesta V Power Station
सिंगतम, पूर्वी सिक्किम - 737134
Singtam, East Sikkim- 737134



IS/ISO 9001 IS/ISO 14001 IS 18001

आई एम एस प्रमाणित पावर स्टेशन

IMS certified Power Station

दूरभाष/Ph: 03592-247349

फ़ैक्स/Fax: 03592-247227/349

	Specifications)		<p>lifting/lowering speed of 50T Capacity RD hoist has neither mentioned in GTS & nor in PTS. In absence of tis data, we are unable to prepare tender stage estimation of mechanical components such Motor, Gear Box, Brake, Coupling & other associated items of RD Hoist.</p> <p>In light of above, you are requested to inform the lifting/lowering speed in this Rope Drum hoist so that we can complete all necessary pre tendering documentation in time.</p>	<p>m/min. Accordingly, necessary technical corrigendum has been made at Clause No. 2.0 of PTS (Particular Technical Specification) of Section-VIII of Tender documents for inclusion of 'Lifting/Lowering speed of Gate: 0.5 m/min (minimum)' under Main data as per Annexure-A.</p>
--	-----------------	--	---	---

Handwritten signature

Corporate Office: NHPC Limited, NHPC Office Complex, Sector-33, Faridabad-121003 (Haryana)

निगम मुख्यालय एन.एच.पी.सी. लिमिटेड : एनएचपीसी ऑफिस कॉम्प्लेक्स, सेक्टर-33, फरीदाबाद-121003(हरियाणा)

Corporate Identification Number (CIN): L40101HR1975GOI032564