



एनएचपीसी लिमिटेड
NHPC LIMITED
(भारत सरकार का उद्यम)
(A Govt. of India Enterprise)
तीस्ता V पावर स्टेशन
Teesta V Power Station
सिंगतम, पूर्वी सिक्किम - 737134
Singtam, East Sikkim- 737134



IS/ISO 9001 IS/ISO 14001 IS 18001
आई एम एस प्रमाणित पावर स्टेशन
IMS certified Power Station
दूरभाष/Ph: 03592-247349
फैक्स/Fax: 03592-247227/349

Ref No. NH/TSV/Cont/ EC-162/NIT-1015/2025-26/ 18

Dated: 26-04-2025

Please refer to Tender invited vide NIT No.: NH/TSV/CONT/EC-162/NIT-1015/2025-26/24
Dated: 21/04/2025 (Tender ID: 2025_NHPC_857224_1) for the work of "Internal Electrification of re-constructed Control Room of 66/11KV Switchyard", the Reply of Employer (NHPC Ltd.) on Techno-Commercial queries (from the prospective bidder through CPP Portal) has been attached herewith as Annexure-A (Reply of Techno-Commercial queries).


For & On behalf of NHPC Limited.

Rabinulles
26/04/25

Gr. Sr. Manager (M)

Contract Division

Teesta - V Power Station



A Navratna Company

एनएचपीसी लिमिटेड

NHPC LIMITED

(भारत सरकार का उद्यम)

(A Govt. of India Enterprise)

तीस्ता V पावर स्टेशन

Teesta V Power Station

सिंगतम, पूर्वी सिक्किम - 737134

Singtam, East Sikkim- 737134



IS/ISO 9001 IS/ISO 14001 IS 18001

आई एम एस प्रमाणित पावर स्टेशन

IMS certified Power Station

दूरभाष/Ph: 03592-247349

फैक्स/Fax: 03592-247227/349

Annexure-A

Reply of Employer (NHPC Ltd.) on Techno-Commercial queries (from the prospective bidder through CPP Portal)

SL. N.	Tender Reference	Description	Pre-Bid query (Techno-Commercial) received	Reply of NHPC LTD.
1	NIT (Section-I) clause no. 1(viii) & SCC (Section-VI) Clause No. 2	COMPLETION PERIOD: - The work should be completed within 15 Days from date of issue of Letter of Award.	To mobilise manpower with tools & plants it will take minimum of 7-days as we are Delhi/NCR based company. Thus, it is hard to complete the work within given (i.e. 15 Days) time period. Thus, we requesting you to, please, increase the work completion period.	Due to site requirements, it is not possible to increase the completion period. Hence No change.
2	Section-VII of Tender Documents (BOQ Item No. 21, 22, 23 & 24)	Use of "recessed alkathine pipe."	In already constructed building, it is easy to install pipes in walls but in ceiling chasing is not permissible due to ceiling strength issues. Thus, please confirm, in ceiling, whether it will be recessed or on surface	All wiring shall be in recessed alkathine pipe.

Corporate Office: NHPC Limited, NHPC Office Complex, Sector-33, Faridabad-121003 (Haryana)

निगम मुख्यालय एन.एच.पी.सी. लिमिटेड :, एनएचपीसी ऑफिस कॉम्प्लेक्स, सेक्टर-33, फरीदाबाद-121003(हरियाणा)

Corporate Identification Number (CIN): L40101HR1975GOI032564

20/01/2024



A Navratna Company

एनएचपीसी लिमिटेड
NHPC LIMITED

(भारत सरकार का उद्यम)
(A Govt. of India Enterprise)
तीस्ता V पावर स्टेशन

Teesta V Power Station
सिंगतम, पूर्वी सिक्किम - 737134
Singtam, East Sikkim- 737134



IS/ISO 9001 IS/ISO 14001 IS 18001
आई एम एस प्रमाणित पावर स्टेशन
IMS certified Power Station
दूरभाष/Ph: 03592-247349
फैक्स/Fax: 03592-247227/349

3	Section-VII of Tender Documents (BOQ Item No. 21 & 22)	"light/fan/call bell & 6 A plug point"	Please confirm, whether it is only wiring or wiring including light point/fan point/call bell point & 6A plug point (i.e. including switch, socket, GI Modular Box & Cover plate with frame etc)	It is only for wiring, all other items are already covered in BoQ
4	Section-VII of Tender Documents (BOQ Item No. 23)	"For 16 Amps(2*1000w) plug point"	Please confirm, whether it is only wiring or wiring including 16A plug point (i.e. including switch, socket, GI Modular Box & Cover plate with frame etc.)	It is only for wiring, all other items are already covered in BoQ.

24/11/20

Corporate Office: NHPC Limited, NHPC Office Complex, Sector-33, Faridabad-121003 (Haryana)
निगम मुख्यालय एन.एच.पी.सी. लिमिटेड : एनएचपीसी ऑफिस कॉम्प्लेक्स, सेक्टर-33, फरीदाबाद-121003(हरियाणा)
Corporate Identification Number (CIN): L40101HR1975GOI032564